

STATEMENT G

Indented Markings

Issued October 1974
Revised September 1986
Revised March 1992
Revised May 2000
Revised December 2009
Revised May 2017

When pipe or tubing is marked by indentation, care should be taken to ensure that the markings do:

1. not reduce the wall thickness to less than the minimum value for the pipe.
2. not have any effect on the long-term strength of the pipe.
3. not provide leakage channels when elastomeric gasket compression fittings are used to make the joints.

The indented print line should be in a color that contrasts with that of the pipe, or a separate print line should be in a color that contrasts with the pipe.